

External Review Comments Received and Responses for Draft New & Revised Standard Details of September 30, 2024

No.	Standard Detail Alpha-Numeric	Comment	By	Date	Response by Standard Details Multi-departmental Interdisciplinary Team Germane Members	Means
1	W-10	" ... have not checked the current International Plumbing Code, but not too many years ago the frostline for McLennan County was 12" below grade; therefore, all water service piping was a minimum of 12" deep. The new water meter detail specifies 8" minimum and 12" max. I think that you should confirm the min. Building Code depth requirements and then have the associated water service details compliment the Code.	George E. "Jed" Walker, Jr., P.E., President, Walker Partners	10/3/2024	A decision on the water service depth within the Standard Detail is pending further research and discussion with Water Utilities Services Department.	
2						
3						
4						
5						