

ANCHOR BOLTS TO BE PER POLE MANUFACTURER AND INSTALLED USING TEMPLATE FURNISHED BY POLE MANUFACTURER FOR ALIGNING ANCHOR BOLTS. SEE NOTE 5 DETAIL [T-2A](#).

CONSTRUCT LEVEL ACROSS TOP OF FOUNDATION BASE

1 IN. CHAMFER

2 IN. PVC SCH. 40

8' GROUND ROD

TOP OF CONCRETE TO BE AT BOTTOM OF BOLT THREADS

TOP OF FINAL FINISHED ADJACENT GRADE

VARIES. SEE NOTE 7, DETAIL [T-2B](#)

24 IN.

SEE NOTE 7, DETAIL [T-2B](#)

4 IN.

12 IN.

18 IN.

ANGLE IRON WELDED TO ANCHOR BOLTS

2 IN.

12 IN.

36 IN.

REBAR WELDED CAGE

SEE STANDARD DETAIL [G-7](#) GENERAL CONCRETE & REINFORCEMENT NOTES

12 IN.

6 IN.

24 IN. Ø

SECTION VIEW

**NOTES:**

LIGHT POLES SHALL BE INSTALLED A MINIMUM OF 2 FT. OFFSET FROM BACK OF CURB. MEASUREMENT IS FROM FACE OF FOUNDATION TO BACK OF CURB.

**ANTIQUE STREET LIGHT REINFORCED FOUNDATION**

(NO SCALE)



**ENGINEERING DIVISION**

**DISCLAIMER:** THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES RESULTING FROM ITS USE.

REVISIONS			
NO.	COMMENTS	BY	DATE
##	DESCRIPTION	FL	MM/DD/YYYY

DATE  
01/01/2024

T-3