



**NOTES:**

1. THIS DETAIL SHALL BE USED FOR SEWER DEPTHS GREATER THAN 10 FT.
2. EXISTING MAIN REQUIRES A GASKETED, RIGID, WYE AND A COUPLING THAT RESISTS SHEARING.
3. THRUST BLOCKING UNDER ALL FITTINGS. REFERENCE [W-3A](#), [W-3B](#), [W-3C](#), [W-3D](#), AND [W-3E](#). (MIN. 6 IN. OF CONCRETE AROUND ALL JOINTS (TYP.))
4. REFERENCE [G-8](#) AND [G-10](#) FOR PIPE EMBEDMENT REQUIREMENTS.

**DEEP SANITARY SEWER SERVICE CONNECTION**

(NO SCALE)



**ENGINEERING DIVISION**

DISCLAIMER: THE USE OF THIS STANDARD IS GOVERNED BY THE "TEXAS ENGINEERING PRACTICE ACT". NO WARRANTY OF ANY KIND IS MADE BY THE CITY OF WACO FOR ANY PURPOSE WHATSOEVER. THE CITY OF WACO ASSUMES NO RESPONSIBILITY FOR THE CONVERSION OF THIS STANDARD TO OTHER FORMATS OR FOR INCORRECT RESULTS OR DAMAGES RESULTING FROM ITS USE.

REVISIONS			
NO.	COMMENTS	BY	DATE
1	MODIFY NOTE 1; ADD NOTE 2; RENUMBER NOTES; MODIFY DETAIL NOTES TO MATCH NUMBERED NOTES	MZ	11/15/2024
##	DESCRIPTION	FL	MM/DD/YYYY

DATE  
01/01/2024

**S-3**